

## NOTES:

- 1. SAMPLING STATION SHALL BE LOCATED BEHIND THE SIDEWALK, AND WITHIN PUBLIC R/W OR DEDICATED EASEMENT TO WWD8.
- 2. IN CORROSIVE SOIL, PEX-A MAY BE SUBSTITUTED FOR THE 1" COPPER SERVICE LINE UPON APPROVAL.
- 3. ALL MATERIALS AND CONSTRUCTION SHALL MEET THE REQUIREMENTS AS SPECIFIED IN THE DISTRICT'S WATER DESIGN AND CONSTRUCTION STANDARDS MANUAL.
- 4. PRE-APPROVED MANUFACTURES AND MODEL NUMBERS ARE LISTED IN THE DISTRICT'S APPROVED MATERIALS LIST FOR WATER IMPROVEMENT PROJECTS.

