



NOTES:

1. PIPE SIZES 8" AND UNDER = GATE VALVES, PIPE SIZES 10" OVER = BUTTERFLY VALVES
2. ALL MATERIALS AND CONSTRUCTION SHALL MEET THE REQUIREMENTS AS SPECIFIED IN THE DISTRICT'S "WATER DESIGN AND CONSTRUCTION STANDARDS" MANUAL.
3. PRE-APPROVED MANUFACTURES AND MODEL NUMBERS ARE LISTED IN THE DISTRICT'S "APPROVED MATERIALS LIST FOR WATER IMPROVEMENT PROJECTS."



**Ventura County  
Waterworks  
District No. 8**

CUT-IN TEE

SEP 2022

RECOMMENDED:

/s/

DEPUTY DIRECTOR / DISTRICT ENGINEER

APPROVED:

/s/

DIRECTOR OF PUBLIC WORKS

PLATE  
303