



NOTES:

1. SEE PLATES 201–206 FOR WASTEWATER LINE CROSSING REQUIREMENTS.
2. CONCRETE STRENGTH SHALL BE 3000 PSI. (MINIMUM)
3. ENCASEMENT SHALL EXTEND BEYOND THE EDGE OF THE OBSTRUCTION IN BOTH DIRECTIONS AN EQUAL DISTANCE FROM THE WATER MAIN TO THE OBSTRUCTION.
4. ENCASEMENT ALONG THE WATER MAIN SHALL EXTEND UNTIL DEPTH OF PIPELINE COVER REACHES 42”.
5. ALL MATERIALS AND CONSTRUCTION SHALL MEET THE REQUIREMENTS AS SPECIFIED IN THE DISTRICT’S “WATER DESIGN AND CONSTRUCTION STANDARDS” MANUAL.
6. PRE-APPROVED MANUFACTURES AND MODEL NUMBERS ARE LISTED IN THE DISTRICT’S “APPROVED MATERIALS LIST FOR WATER IMPROVEMENT PROJECTS.”

 <p>Ventura County Waterworks District No. 8</p>	WATER PIPELINE ENCASEMENT		JUL 2021
	RECOMMENDED: <i>/s/</i> DEPUTY DIRECTOR / DISTRICT ENGINEER	APPROVED: <i>/s/</i> DIRECTOR OF PUBLIC WORKS	PLATE 302