

## **NOTES:**

- 1. #4 @ 16 INCHES O.C. BOTH WAYS.
- 2. CONCRETE TO BE VIBRATED.
- 3. THE MINIMUM DISTANCE BETWEEN TOP OF SLAB AND BOTTOM OF SUBGRADE (IF PAVED) OR FINISHED SURFACE (IF NOT PAVED) SHALL BE 6 INCHES AND 12 INCHES RESPECTIVELY.
- 4. THIS DETAIL MAY BE USED FOR SHALLOW TRENCHES.
- 5. BACKFILL SHALL COMMENCE WHEN THE CONCRETE STRENGTH IS 75% OF THE SPECIFIED STRENGTH.
- 6. BEDDING MATERIAL SHALL BE COMPACTED TO 90% RELATIVE DENSITY.

APPROVED:

/S/
DIRECTOR OF PUBLIC WORKS
Aug 28,2006
DATE

CITY OF
SIMI VALLEY

DEPARTMENT OF PUBLIC WORKS

REINFORCED CONCRETE
TRENCH SLAB

STANDARD PLAN NO.

SV 40-70

SHEET 1 OF 1