



**NOTES:**

1. APPROVAL FOR THE LOCATION OF THE SAMPLING WELL SHALL BE OBTAINED FROM THE ENVIRONMENTAL COMPLIANCE DIVISION PRIOR TO INSTALLATION.
2. WHEN INSTALLING THE SAMPLING WELL, BE SURE THAT THE INVERT OF THE SAMPLING WELL IS LEVEL WITH THE INVERT OF THE INLET AND OUTLET PIPES.
3. FOR PLASTIC SEWER PIPE, PLACE TIGHT FITTING RUBBER RING OVER PIPE AT MIDPOINT WHERE IT PASSES THROUGH CONCRETE WALL.

APPROVED:

/S/

DIRECTOR OF PUBLIC WORKS

Aug 28, 2006

DATE

CITY OF  
SIMI VALLEY

DEPARTMENT OF PUBLIC WORKS

SAMPLING WELL

STANDARD PLAN NO.

SV 40-250

SHEET 1 OF 1